

# Findings of the Cyclowest Radiation Survey for the GE PETtrace Cyclotron at the Bayswater Site

Dr Samer Bakr



### Contents



- Overview of Cyclowest site in Bayswater
- Cyclotron and Radiation Fields
- RP For Workers, Public and Environment
- Shielding for Neutrons
- Effectiveness of Neutron Barrier for Gammas
- Radiation Survey Study
- Conclusion

#### PROPERTY OF CYCLOWEST HOLDINGS PTY LTD

#### Bayswater WA

- The state currently has only one facility, operated by the WA government, and it is unable to meet the full level of demand in Perth.
- Cyclowest exists to meet the current rapidly growing demand for PET radiopharmaceuticals in WA.
- Our new private service will complement this and expand the overall capacity of the health sector to diagnose and treat West Australians.





SCHEMATIC OF THE COMPLETED WAREHOUSE

28

C

9

0

.

۲

0

-



CYCLOWEST HOLDINGS PTY LTD

PROPERTY OF CYCLOWEST HOLDINGS PTY LTD

# **Principle of Operation**



- NEGATIVE IONS are CREATED in the center of the cyclotron.
- IONS are EXTRACTED from the Ion Source using Alternating High Voltage.
- IONS are ACCELERATED using Alternating High Voltage.
- IONS are KEPT IN ORBIT by a Static Magnetic Field.
- IONS' POLARITY is CHANGED from negative to POSITIVE using a stripping foil.
- POSITIVE IONS bend in the opposite direction in the magnetic field.
- Positive lons BOMBARD THE MEDIA in the Target.













• These lead plates will be adjusted inside the tanks for extra shielding before filled with borated water.



• The tanks from inside.













#### GAMMA DOSE RATE CONTOURS (µSv/h)

18F- production on enriched water (>95%). 160 μA total beam current.

13





#### PROPERTY OF CYCLOWEST HOLDINGS PTY LTD

VEST



#### **Bunker Configuration**

Neutrons





PROPERTY OF CYCLOWEST HOLDINGS PTY LTD

Gamma





PROPERTY OF CYCLOWEST HOLDINGS PTY LTD



# Maximum Permissible Dose Rate CYCLOWEST

10% Occupational Annual Dose Limit
$$(20\frac{mSv}{h}) = 2\frac{mSv}{h} = 40\frac{\mu Sv}{week} = 1\frac{\mu Sv}{h}$$

50% Public Annual Dose Limit $\left(1\frac{mSv}{h}\right) = 500\frac{\mu Sv}{h} = 10\frac{\mu Sv}{week} = 0.25\frac{\mu Sv}{h}$ 

# **Shielding for Neutrons**

- NCRP 51 [Dose per N<sub>flux</sub> vs T<sub>Concrete</sub>]
- Ratio [neutron dose rate/public dose rate] [21/0.25=84]
- N<sub>flux</sub>/84  $\rightarrow$  45 cm of concrete.
- NCRP 51, NCRP 144 (+HVL)
- = 55 cm of concrete
- Extra safety (+10 cm)
- = 65 cm of concrete
- 65 cm = 160 g.cm<sup>-2</sup>  $\rightarrow$  N<sub>flux</sub> (0)/ N<sub>flux</sub> (160) = 300
- 21 µSv/h / 300 =0.07 µSv/h





# Effectiveness of Neutron Barrier for Gamma



• 
$$I = I_0 \div 2^{\left(\frac{x}{HVL}\right)} \rightarrow I\left[\mu\frac{Sv}{h}\right] = 21\left[\mu\frac{Sv}{h}\right] \div 2^{\left(\frac{65\left[cm\right]}{12\left[cm\right]}\right)} = 0.49 \ \mu Sv/h$$

•  $0.07 + 0.49 = 0.56 \,\mu Sv/h$ 

Control Room 
$$\frac{2 \times 250}{2000} = 0.25 \rightarrow 0.56 \times 0.25 = 0.14 \ \mu Sv/h < 1 \frac{\mu Sv}{h}$$
  
Car Park  $\frac{0.5 \times 250}{2000} = 0.0625 \rightarrow 0.56 \times 0.0625 = 0.035 \ \mu Sv/h < 0.25 \frac{\mu Sv}{h}$ 



Bunker floor level setting



![](_page_21_Picture_0.jpeg)

![](_page_22_Picture_0.jpeg)

![](_page_23_Picture_0.jpeg)

### **Radiation Survey Study 01**

![](_page_24_Picture_1.jpeg)

![](_page_24_Figure_2.jpeg)

![](_page_25_Picture_0.jpeg)

Dose rate range (µSv/h)	
0 to 0.3	
0.3 to 10	
10 to 200	
200 and higher	

![](_page_25_Figure_2.jpeg)

LDINGS PTY LTD

#### Radiation Survey Study Gamma 03

![](_page_26_Picture_1.jpeg)

Dose rate range (µSv/h)	
0 to 0.3	
0.3 to 10	
10 to 200	
200 and higher	

![](_page_26_Figure_3.jpeg)

![](_page_26_Picture_4.jpeg)

LDINGS PTY LTD

### Conclusion

![](_page_27_Picture_1.jpeg)

- The barrier thickness has been determined for a GE PETtrace cyclotron
- A comprehensive radiation study was carried out using advanced equipment.
- The study covered multiple monitoring locations within and outside the facility.
- The Radiological Council of Western Australia's guidelines for radiation worker dose limits were considered.
- Notable gamma hotspots were found in the cyclotron's self-shielding tanks inside the bunker.
- These however do not result in any measurable elevated radiation dose rates outside of the bunker.
- This investigation confirms that cyclotron operational dose rates remain well within established safety thresholds.
- The overall radiation impact of the cyclotron on both the neighbours and the environment is deemed negligible and therefore well within acceptable limits.